



Protecting, Maintaining and Improving the Health of All Minnesotans

October 12, 2023

City of Rushford Village
c/o Ms. Mary Miner, Clerk
43038 State Highway 30 West
Rushford Village, Minnesota 55971 - 5167

Water System Owner/Operator:

SUBJECT: Lead/Copper Tap Water Monitoring Report, PWSID 1230014

This letter is to report the results of your recent lead/copper monitoring that is required by the Safe Drinking Water Act. The results revealed the following 90th percentile levels:

90th percentile lead level = $<1 \mu\text{g/l}$ (rounded as $< 0.001 \text{ mg/l}$).
The action level for lead is $15.0 \mu\text{g/l}$.

90th percentile copper level = $645 \mu\text{g/l}$ (rounded as 0.645 mg/l).
The action level for copper is $1300 \mu\text{g/l}$.

Based on these results, your public water system **has not exceeded** the action level for lead and **has not exceeded** the action level for copper.
